

## RECOMMENDATIONS

1. The City of Thomasville should have a consultant engineer prepare plans for the expansion of the water treatment plant and other elements of the distribution system.
2. The City of Thomasville should continue its program of eliminating substandard water by replacing existing substandard water lines with larger lines.
3. The size of new water pipes should be capable of handling water for those areas on the fringe of the City that are not now a part of the City, but could be at some date in the future.